Carbon Monoxide Alarms - Trouble Shooting Guide

FireBlitz EXTINGUISHER

Firehawk SAFETY PRODUCTS

My Alarm keeps beeping

- Once per minute → **Low battery warning.** – will probably start at night when the batteries are at their coldest. As the battery continues to get weaker the beeping will become more frequent until it is doing it at all times of day.
  The battery is not replaceable so replace the alarm. If the alarm is less than 10 years old, contact the installer or the manufacturer.
- Two rapid beeps per min → **Fault signal** --- if the alarm is less than 10 years old, contact the installer or the manufacturer.
- Three rapid beeps per minute → **End of life alarm** If problem persists and the alarm is less than 10 years old, contact the installer or the manufacturer.
- Repeating series of four beeps with a red LED → ***Full alarm***

  EVACUATE THE PROPERTY AND CALL THE EMERGENCY SERVICES
- Nuisance alarm → If you have been advised by an approved Gas Safe Engineer the you have had a nuisance alarm – Contact Fireblitz for further information and guidance.

My Alarm is flashing a Yellow Light → This is a fault --- if the alarm is less than 7 (or 10 if it is a CO7B10y) years old, contact the installer or the manufacturer for an immediate replacement

My alarm is completely dead → Does it work when tested?

- No → Contact the installer or manufacturer
- Yes → Is the sounder working when tested?
  - No → Contact the installer or manufacturer
  - Yes → Contact the manufacturer for advice